

Accident Scenarios for ATF Performance Evaluation of BWR and PWR in Japan

Central Research Institute of Electric Power Industry,
Japan Atomic Energy Agency,
Global Nuclear Fuel - Japan Co., Ltd.,
Hitachi-GE Nuclear Energy, Ltd.,
Mitsubishi Heavy Industries, Ltd.,
Mitsubishi Nuclear Fuel Co., Ltd.,
Nippon Nuclear Fuel Development Co., Ltd.,
Nuclear Fuel Industries, Ltd.,
Toshiba Corporation

EGATFL 3rd meeting

3rd-5th March 2015

OECD/NEA HQ, Paris

Purposes

To evaluate quantitatively the improvement in safety performance by introducing ATF concepts into current commercial LWR plants, the following preconditions are determined.

- **Reference plant: Reactor type and output scale**

Representative BWR & PWR where ATF will be introduced.

- **Severe accident (SA) scenario**



A typical and simple scenario for each of BWR & PWR,
Common sequence independent of a specific NPP site condition

The reference plant for ATF performance evaluation (BWR)

We selected a **large scale Boiling Water Reactor (BWR)** as a reference plant of BWR for ATF performance evaluation.

The following information is needed for evaluation,


- ✓ Detailed plant information such as fuel type, RPV configuration, PCV size, etc.
- ✓ Appropriate scenario for the reference BWR



Plant information for ATF performance evaluation (BWR)

Major plant information for the reference BWR is shown below.

Items	Reference BWR
Thermal power	3926MWt
Fuel type	9x9
Number of fuel assemblies	872
Control rod type	Cross shaped control blade
Number of control rods	205
Neutron absorber	B ₄ C
RPV diameter	About 7.1m
RPV height	About 21m
ATF applications for:	Fuel cladding, channel box



Appropriate scenario for ATF performance evaluation (BWR)

The accident scenarios of the reference BWR are categorized based on timing and mode of RPV/core/PCV failures as well as availability of measures for molten debris cooling and heat removal. Representative scenarios are grouped into 6 PDSs (Plant Damage States) shown below:

•TQUV	The PDS “TQUV” is Transient (T) including planned manual shutdown and special initiators, followed by failures of feed water system (Q), high pressure ECCS (U) and low pressure ECCS (V).
•TQUX	The PDS “TQUX” is Transient (T) including planned manual shutdown and special initiators, followed by failures of feed water system (Q), high pressure ECCS (U) and reactor depressurization (X).
•LOCA	This PDS includes AE: large LOCA (A) with injection failure (E), S1E: medium LOCA (S1) with injection failure (E) and S2E small LOCA (S2) with injection failure (E).
•TW	Water injection to the core is successful but heat removal from PCV fails (W).
•TC	Water injection to the core is successful but heat removal from PCV is not enough due to failure to remain subcritical (C).
•TB	In station blackout (TB), including failure to recover offsite power by 30 minutes and by 8 hours, high pressure injection is maintained until DC power is exhausted.

TW and TC are milder on H₂ generation than TQUV because core cooling functions are available.

A frequency of occurrence of TQUV is higher than TQUX and TB as well as LOCA because depressurization measures and power recovery measures are strengthened for the latest typical BWR, therefore TQUV has a priority on ATF performance evaluation.

⇒ **TQUV*** is selected as the representative PDS for ATF performance evaluation in BWR from the viewpoint of H₂ generation rate and its frequency of occurrence.



*Anticipated transient with failures of feedwater system, high-pressure ECCS & low-pressure ECCS.

The reference plant for ATF performance evaluation (PWR)

We selected a large scale Pressurized Water Reactor (PWR) as a reference plant of PWR for ATF performance evaluation.

The following information is needed for evaluation.


- ✓ Detailed plant information such as fuel type, RPV configuration, etc.
- ✓ Appropriate scenario for ATF performance evaluation using the reference PWR



Plant information for ATF performance evaluation (PWR)

Major plant information for the reference PWR are shown below.

Items	Reference PWR
Thermal power	3,411MWt
Fuel type	17x17
Number of fuel assemblies	193
Control rod type	Rod cluster control assemblies
Number of control rods	53
Neutron absorber	Ag-In-Cd
RPV diameter	About 4.4 m
RPV height	About 12.9 m
ATF applications for:	Fuel cladding



Reference PWR (4 loops)

Appropriate scenario for ATF performance evaluation (PWR)

The accident scenarios of the reference PWR are grouped into 22 PDSs (Plant damage states). PDSs are represented by combination of three letters shown below:

▪ RCS pressure at RV failure (High: T**, Medium: S**, Low : A**)
▪ Timing of core damage (Early: *E*, Late : *L*)
▪ Timing of containment failure (Before core damage: **C, After core damage: **D, **F, **W, **H, **I) ▪ Availability of molten debris cooling measures (Available: **W, **H, **I, Unavailable: **D, **F) ▪ Availability of containment heat removal measures (Available: **F, **H, **I, Unavailable: **D, **W)
▪ Containment bypass (V, G)

Core damage in earlier phase of accidents is severer for ATF performance evaluation, and also lower RCS pressure is severer in terms of the pressure difference between the inside and outside of the fuel pin. Then AE* is appropriate.

AEF, AEW, AEH and AEI are comprehended by AED because containment condition is not dominant.

⇒ AED is selected as the representative PDS for ATF performance evaluation in PWR.
 *: A large break LOCA combined with failures of ESSC and heat removal from containment vessel

Summary

Reference plant & SA scenario were selected for ATF performance evaluation in Japan.

BWR

Output scale: 3,926MWt

Fuel type: 9x9

CR type: Cross shaped (B_4C)

SA scenario: TQUV

Depressurization and power recovery measures are strengthened based on a lesson from Fukushima-Daiichi accident.

PWR

Output scale: 3,411MWt

Fuel type: 17x17

CR type: Cluster (Ag-In-Cd)

SA scenario: AED

The severest accident scenario assumed in PWRs were selected as a representative PDS.

Based on these preconditions, the ATF performance will be analytically evaluated using SA analysis code.

Thank you for your attention !!